



# Stormwater BMP Inspection Checklist

## Grassed Swales

Development Name: \_\_\_\_\_

Address: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

BMP Feature	Potential Problem	Maintenance Needed	✓
The entire swale	Trash or debris is present	Remove trash/debris.	<input type="checkbox"/>
	Exposed soil and/or gullies are present	Regrade soil if necessary to remove gully, then plant ground cover and water until established. Provide lime and one-time fertilizer application.	<input type="checkbox"/>
	Sediment accumulation covers the grass at the bottom of the swale	Remove sediment and dispose in an area that will not impact streams or BMPs. Re-sod if necessary.	<input type="checkbox"/>
	Vegetation is less than 4 inches or greater than 8 inches	Mow vegetation to height of approximately 6 inches.	<input type="checkbox"/>
The receiving water	Erosion or other signs of damage have occurred at the outlet	Consult a professional.	<input type="checkbox"/>

### Comments

---



---



---