



Nick Ingold
Engineer Technician

Currituck County

153 Courthouse Road, Suite 302
Currituck, North Carolina 27929
252-232-6048
FAX 252-232-3298
Nick.Ingold@CurrituckCountyNC.gov

ADDENDUM No. 1

Date: December 18, 2020

To: Prospective Bidders and Others Concerned

From: Currituck County

RE: Carova Roads Repair

The following shall take precedence over the plans and specifications and shall become part of the Contract Documents. Please acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to acknowledge this addendum may result in your bid being declared non-responsive.

1. Bid Date and Time
 - a. Currituck County office's will be closing at 12:00 p.m. on December 23, 2020. Bid submissions are due to the County by 11:00 a.m. on December 23, 2020.
2. Culvert Class
 - a. Specifications and plans identify 18" reinforced concrete pipe (RCP) culverts with a minimum soil cover of 12 inches. Based on NCDOT Appendix H – NCDOT Pipe Material Selection Guide, RCP material class shall be CLASS IV.
3. Staging Area
 - a. Contractor may use the outlined portion of the gravel parking lot at the Historic Corolla Park as a staging area for material/equipment drop-off and pick-up (see Figure 1). Items in this area shall be placed in a neat, organized manner and shall not impede ingress and egress of the parking lot. The outlined portion of the gravel parking lot and any other damage caused from using this area shall be reconstructed to its previous condition upon completion of its use. The County is not responsible for any material/equipment staged in this area.

